

DIVISION OF INDUSTRY SERVICES
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor Dave Ross, Secretary

March 31, 2016

VISTA RESEARCH GROUP, LLC JIM CHANDLER 1554 TOWNSHIP ROAD 805 PO BOX 321 ASHLAND OH 44805

Re: Description: HEALTH CARE PLUMBING APPLIANCE

Manufacturer: VISTA RESEARCH GROUP, LLC Product Name: (trans id 2687674) VISTACOOL

Model Number(s): V7501 AND V7502

Product File No: 20160099

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2021.

This approval is contingent upon compliance with the following stipulation(s):

- These devices shall be installed in accordance with the manufacturer's published instructions.
- These devices may be used can be used with the following specific autoclaves:

Midmark/Ritter M3 Midmark/Ritter M9* Midmark/Ritter M11* SciCan STAT/M 2000 SciCan STAT/M 5000

The autoclave served by a Vistacool device shall be a state approved healthcare plumbing appliance. The use of the Vistacool devices on autoclaves other than those specified above must be specifically approved by the manufacturer, in writing. Vistacool devices installed without written approval from the manufacturer may be ordered removed.

- Cross connection control is not required on the water supply feeding these devices. This is because cross connection control precedes the autoclaves, which are installed upstream of the Vistacool devices.
- These devices shall discharge via an air gap that conforms to ASME A112.1.2 or A112.1.3.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

SBD-10564-E (N.10/97) File Ref: 16009902.DOC

^{*} Requires Model V7502 and S7560 adapter kit

Vista Research Group LLC March 31, 2016 Page 2 of 2 Product File No.: 20160099

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Depart of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail